

**Government of Bihar
Public Health Engineering Department
Water Quality Report**

District Name:- Nalanda

Division Name:- Public Health Division Bihar Sharif & Hilsa

Format: I

Sample Collected by:- Biju Singh

Date of Sampling:- 24/05/2024

Sl. No.	Block	Panchayat	Village	Location of Source	Test result													Source of water
					pH	Turb.	EC	TDS	TH	Ca	Mg	Cl	Alka.	Fe	NO ₃	SO ₄	F	
2	3	4	5		6	7	8	9	10	11	12	13	14	15	16	17	18	
	Siac	Nanand	Sainik School Nanand	Sainik School Nalanda	7.29	0.4	483	300	135	34.2	16.3	34.2	145	0.14	0.22	43	0.002	Tubewell
Desirable Limit*					6.5-8.5	1.0	-	500	300	75	30	250	200	1.0	45	300	1	
Permissible Limit* in absence of alternate source					NR	5.0	-	2000	600	200	100	1000	600	NR	NR	400	15	

Self attested

Bhupendra Kumar
(Bhupendra Kumar)
Col
Principal
Sainik School Nalanda

H. Danda
Chemist 20/5/2024
Public Health Division Bihar Sharif
(Nalanda)
Chemist
Public Health Division
Bihar Sharif (Nalanda)